

Addendum – 2 – Reply to Prebid queries

S. No.	Topic/ Page No./ Clause No.	Description	Suggested Modification/ remark	Reply
1	Eligibility Criteria Page no. 23 Clause no. 2.4		The Technology provider should be able to quote as an EPC Contractor	Yes. Also refer point no.3 of Addendum – 1 reply to the queries.
2	Payment Clause page no. 37 of 549 clause no. 2.29.3	10 % mobilization advance against the bank guarantee and other hand 20% amount of each running bill will be deducted against mobilization advance and other payment terms are not viable for project positive cash flow.	Should have a relook on the same. Contractor should be given a fair play and allowed to quote the Neutral Payment Terms	No change.
3	Payment Cycle page no. 37 of 549 clause no. 2.29.3	Payment will be done within 40 days on presentation of bill.	Should be released in 7 days	No change
4	Water & electricity page no. 35 of 549 clause no.2.30.1	contractor should arrange its own	The Water & Electricity will be Provided by the Employer however the same will be paid by the Contractor	No change
5 A	Specific Requirement for Process unit : Point No. 1.2.4 on page no.390 of 549 for SWD of raw sewage	SWD of raw sewage sump mentioned 1.5 m	Suggested atleast 2.0 m.	As per the requirement, bidders are free to increase the sizes to meet their operation requirement and guaranteed output quality

	sump mentioned 1.5 m			
5 B	<p>Specific Requirement for Process unit :</p> <p>SBR : Point no. 1.4 on page no. 392 of 549</p>	Size of SBR tank , no. of tank , treatment philosophy , cycle timing mentioned in tender	Suggested as per the Technology providers design.	The sizes indicated in the tender document are reference purpose only. Bidders are free to increase the sizes as per the technology providers design to meet the required output quality.
5 C	<p>Specific Requirement for Process unit :</p> <p>Sludge Sump : Point on 1.6 on page no. 393 of 549</p>	Size of sludge sump on the basis of technology provider mentioned in tender	Suggested as it should be as per the technology provider design.	Refer reply to the point no. 5B
6 A	<p>Specific Requirement for Mechanical :</p> <p>Air Blower Point No. 7 on page no.401 of 549</p>	Capacity of blower mentioned in tender	It should be as per the technology providers design.	Refer reply to the point no. 5B
6 B	<p>Specific Requirement for Mechanical :</p> <p>Decanter : Point no. 8 on page no. 402 of 549</p>	Decanter designed travel time, hydraulic loading on decanter mentioned in tender	It should be as per the technology providers design.	Agreed. Also Refer reply to the point no. 5B
6 C	<p>Specific Requirement for Mechanical :</p> <p>RAS & SAS Pump : Point on 10</p>	Capacity and requirement of those pump mentioned in the tender	It should be as per technology providers design.	Refer reply to the point no. 5B

	& 11 on page no. 402 of 549			
7	In the suggested list of manufacturers, page no.527 of 549, point no.5	AIR Diffusers	Sanitaire from Xylem is requested to be one of the approved makes	Agreed.
8			In view of the financial year ending activities and bank holidays request you to kindly extend the last date of submission of tender to 10.04.13	No change